In accordance with ACCA Manual J

Registered For:

The Patrick Campbell Residence

For: Patrick Campbell
123 Some Road
Warren, VT 05674

Design Conditions: Burlington

Indoor:		**Outdoor:**	
Summer temperature:	75	Summer temperature:	85
Winter temperature:	68	Winter temperature:	-4
Relative humidity:	55	Summer grains of moisture:	87
		Daily temperature range:	Medium

Building Component	Sensible Gain (BTUH)	Latent Gain (BTUH)	Total Heat Gain (BTUH)	Total Heat Loss (BTUH)
Whole House	**7,207**	**1,433**	**8,640**	**26,518**
First Floor	4,672	1,287	5,959	14,666
Room First Floor	4,672	1,287	5,959	14,666
Entire Basement	0	0	0	3,536
Basement	0	0	0	3,536
Entire Second Floor	2,535	146	2,681	8,316
Room Second Floor	2,535	146	2,681	8,316
Whole House	**7,207**	**1,433**	**8,640**	**26,518**

Load calculations are estimates only, actual loads may vary due to weather and construction differences.